



NARODOWY
INSTYTUT
ZDROWIA
PUBLICZNEGO
PAŃSTWOWY INSTYTUT
BADAWCZY
ATEST HYGIENICZNY B.BK.60110.1605.2023



INSPECTION CERTIFICATE № 1714

Consignee, address: CANTAS IC VE DIS TICARET SOGUTMA SISTEMLERI SANAYI A.S.

Country Turkey
Contract № EX 23-008 dd 16.01.2023

We declare that the copper tube are produced according to standard indicated for each product as follow:


CUPPER TUBE REFERENCES			
ORDER NUMBER AND DATE	SIZE	PANCAKE COILS ANNEALED	STANDART REFERENCE
25-05 dd 19.08.2025г.	15,87x1,0x50 000	PANCAKE COILS ANNEALED	EN 12735-1

MECHANICAL TESTS				
Tensile strength, σ , MPa (kgf/mm ²), not less than	Specific elongation δ , %, not less than	Expansion %	Flattening	Hardness HV
246	45	40	comply with	62

CHIMICAL ANALYSIS	Cu-%	P-%	ALLOY
	99,97	0,02	Cu-DHP
	Limit min 99,9	Limit min-0,012 max-0,040	

Dimensional tests-Measured values	
WT. Av.-1,0	OD Av.-15,89

Angren Pipe Plant LLC
Akhangaran district 110300,
Tashkent region Republic Uzbekistan
Tel: +99893 183 53 83, e-mail: sales@angrenpipeplant.com
www.angrenpipeplant.com

Signature of the person responsible

Date 26.08.2025